

# Stretch Code & Schools

DOER briefing for MSBA Designer Roundtable

October 20, 2022

Paul Ormond & Ian Finlayson

# Agenda

- Three levels of code (base, stretch, municipal opt-in)
- Key modifications in the updated Stretch code
- Key modifications in the Specialized code
- School case studies

# Base, Stretch, Specialized – 3 options

## Base Code (IECC 2021)

- New construction in towns & cities not a green community
- **52 communities**

Expected from BBRs:  
**July 2023**

## Stretch Code (2023 update)

- New construction in towns & cities that are a green or stretch community
- **299 communities**

**Residential : Jan 2023**  
**Commercial: July 2023**

## Specialized Code ("Net-Zero")


- New Construction in towns & cities that vote to opt-in to this code
- **Effective date:**  
Typically 6-11 months after Town/City vote

# Model Energy Code Status

- Determination
  - 9.4% site energy
  - 8.8% source energy
  - 8.7% energy cost
  - 8.7% carbon emissions
- Removal of Electric-Readiness
- Removal of EVs
- Includes NZE Appendices



- Determination
  - 4.7% site energy
  - 4.3% source energy
  - 4.3% energy cost
  - 4.2% carbon emissions



# Base, Stretch, Specialized – 3 options

**Base code**

2021 IECC / ASHRAE 90.1- 2019 with modest tweaks



EV ready parking

**Stretch code**

2021 IECC / ASHRAE 90.1- 2019 with key modifications



EV ready parking + Solar ready

**Specialized code**

2021 IECC / ASHRAE 90.1- 2019 with key modifications




EV ready parking + Solar ready  
All Electric OR Net Zero OR electric ready + solar




**STRETCH CODE**

# Stretch code compliance options



# Commercial Stretch – Improved Efficiency



**Thermal Energy  
Demand Intensity  
(TEDI) Limits**

+




**Whole building air-  
leakage limits and  
testing**

+




**Ventilation energy  
recovery**

+




**Thermal bridge  
accounting**



Emissions, electrification, comfort, durability, and resilience benefits



# Thermal Energy Demand Intensity (TEDI)





## Heating TEDI

*Total annual energy **delivered to** the building for space conditioning and conditioning of ventilation air, normalized by area (kBtu/sf-yr)*

## Cooling TEDI

*Total annual energy **removed from** the building for space conditioning and conditioning of ventilation air, normalized by area (kBtu/sf-yr)*

# Connection between TEDI and EUI



Heating TEDI

Heating efficiency

Heating end use (EUI)

Heating end use EUI: **2 kBtu/sf-yr**

Heating efficiency: **320%**

Heating efficiency: **6.4 kBtu/sf-yr**


TEDI is not the same as EUI. TEDI is a measure of envelope performance, air infiltration, and ventilation energy recovery.

EUI is a measure of the above, plus equipment efficiency.

TEDI is demand while EUI is consumption

Regulating TEDI means prioritizing envelope, air infiltration, and energy recovery

# Benefits of TEDI limits



- 85% less heating demand
- Emissions reduced
- Electrification easier
- Comfort
- Durability
- Resilience

# TEDI limits



Size of School building	Heating TEDI limit (kBtu/sf-yr)	Cooling TEDI limit (kBtu/sf-yr)
K-12 school ( $\geq 125,000$ -sf)	2.2	12
K-12 school (75,000 to 125,000)	$2.7 - 0.000004 * \text{Area (sf)}$	$32 - 0.00016 * \text{Area (sf)}$
K-12 school ( $<75,000$ )	2.4	20

*The same models currently used for stretch code compliance also produce TEDI information*



*Strange equations simply draws straight line between values*


# Managing cooling TEDI



## Managing cooling TEDI

- Low solar heat gain coefficient (SHGC) windows
- Recessed windows
- External shading
- Reduced air leakage rate

# Whole building infiltration




Above photo: RDH/Advanced Building Analysis

- Limit of 0.35 cfm/sf at 75 Pa
- Mandatory field testing
- Credit for even lower air infiltration
- Passive House: routinely gets 0.08 cfm/sf at 75 Pa


Above photo: Steven Winter Associates



# Thermal bridge accounting



*Wall studs: recognized by current code*





*Fasteners: Not recognized by current code*

- “Continuous insulation” is NOT continuous. There are fasteners, often metal, which go through the insulation.
- Current stretch code only recognizes thermal bridges caused by wall studs. Current stretch code does not recognize thermal bridges caused by fasteners
- Fasteners have major impact on insulation performance





# Thermal bridge accounting




***Fasteners made from fiberglass  
provide thermal break***

- Solution is to include fasteners that have thermal breaks
- Thermal breaks are often value engineered out because code does not mandate thermal bridge accounting
- Proposed stretch code will mandate thermal bridge accounting which will help protect designs and ensure thermally broken fasteners are used.

# Thermal bridge accounting




1. Parapet Length
2. Slab Lengths
3. Wall to Window Transition Lengths



4. Corner Length
5. Opaque Brick Wall Area
6. Glazing Area

- Many other thermal bridge locations not recognized by current stretch code
  - Continuous insulation
  - Brick shelves
  - Balconies/protrusions
  - Window/wall intersections
  - Parapets
  - Wall/wall intersections
  - Wall/floor intersections
- Updated stretch code does recognize these. Thermal breaks are available for all these locations

# Electrification benefits




***Peak electric use ELEC  
heated building built to  
proposed stretch code***

***Peak electric use GAS  
heated building built  
to current stretch code***

The proposed stretch code allows transition to electric heating (from gas) without increasing peak electric.

# Durability benefits




A focus on heating/cooling TEDI results in:

- Smaller HVAC systems
- More robust envelope
- Less moving parts

# Resilience/comfort benefits



Indoor Temperature During Winter Power Outage (°F, 7 days in January)




Current Stretch Code

Proposed Stretch Code

If power is lost, current stretch code building quickly goes to almost 40 F interior

Proposed stretch code – always stays above 55 F interior.

# Emissions benefits




***Overall reduction in energy use seems modest (15%)***

***However, heating end use is significantly reduced (90%)***

# Emissions benefits




### Energy Use Intensity



**Overall reduction in energy use seems modest (15%)**

**However, heating end use is significantly reduced (90%)**

### Emissions in 2050



**The payoff is huge reduction in building emissions (75%)**



# EV READY WIRING

---





# Minimum 10% of spaces wired for Level II EVSE


- Recommended to use load management (ALMS)
- Options to use Level I for more spaces or DC fast-charging

**TABLE C405.13.1 EV-READY PERFORMANCE REQUIREMENTS**

<u>Circuit Breaker Amperage</u>	<u>Maximum Parking Spaces that May Share a Branch Circuit with 10%-60% EV Ready spaces</u>	<u>Maximum Parking Spaces that May Share a Branch Circuit with 61-100% EV Ready spaces</u>
<u>40A</u>	<u>1</u>	<u>2</u>
<u>50A</u>	<u>1</u>	<u>2</u>
<u>60A</u>	<u>2</u>	<u>4</u>
<u>70A</u>	<u>3</u>	<u>6</u>
<u>80A</u>	<u>4</u>	<u>8</u>
<u>90A</u>	<u>5</u>	<u>9</u>
<u>100A</u>	<u>6</u>	<u>10</u>

# EV wiring with ALMS – Advanced Load Management Systems for multiple vehicles

- Dedicated circuits to each vehicle (Current IECC model code language) lead to high installed capacity requirements
- Larger shared circuits allow multiple vehicles to charge at different rates, allowing similar charging while lowering electric capacity requirements (Canadian & Australian model language)





# SPECIALIZED CODE

# Base, Stretch, Specialized – 3 options

**Base code**

2021 IECC / ASHRAE 90.1- 2019 with modest tweaks



EV ready parking

**Stretch code**

2021 IECC / ASHRAE 90.1- 2019 with key modifications



EV ready parking + Solar ready

**Specialized code**


2021 IECC / ASHRAE 90.1- 2019 with key modifications



EV ready parking + Solar ready


All Electric OR Net Zero OR Electric ready + Solar

# Specialized (Municipal opt-in) Code



TEDI limits  
Air infiltration  
Ventilation energy recovery  
Thermal bridging

Meet all the requirements of stretch code



# Specialized code - Requirements

- Key Efficiency requirements in Stretch code
- All –electric or Pre-wired for Electrification
- Solar PV on available space – minimum size
- EV ready 10% of spaces minimum

# Solar PV

- Required:
  - Using Fossil fuels
  - Using Net Zero path
- Optional:
  - All-electric school
- Exceptions for shaded sites can reduce min. size



# Solar PV minimum sizing

**CC105.2 On-site renewable energy.** New mixed-fuel buildings shall have equipment installed for on-site renewable energy with a rated capacity of not less than 1.5 W/ft<sup>2</sup> (16.1 W/m<sup>2</sup>) multiplied by the sum of the gross conditioned floor area of the three largest floors.


**Exception:** Where the building site cannot meet the requirement in full with an on-site renewable energy system, the building site shall install a partial system designed to utilize not less than 75% of the *Potential Solar Zone Area*.

Examples of minimum Solar PV size:

- 4 story 200,000 sf High school: 160,000 sf on 3 largest floors  
Min. Solar =  $1.5 \times 160,000 = 240$  kW system
- 3 story 80,000 sf Elementary  
Min. Solar =  $1.5 \times 80,000 = 120$  kW system



# Net Zero with On-site renewables





# CASE STUDIES

---

- 74,000 sf Primary School
- 328,000 sf Secondary School


# Case study: 74,000-sf primary school

Item	Current Stretch Code	Proposed Stretch Code
Roof	R-40	R-45
Wall	R-19 + 8.4 c.i.	R-19 + 21 c.i.
Thermal breaks	None	Included
% fenestration	22%	
Fixed window	U-0.33 (R-3.0 equiv)	U-0.23 (R-4.3 equiv)
Operable window	U-0.39 (R-2.6 equiv)	U-0.28 (R-3.6 equiv)
Infiltration	1 cfm at 75 Pa	0.4 cfm at 75 Pa
Infiltration testing	No	Yes
Heating plant	Gas mid-efficiency	Gas condensing OR air source VRF
Heating terminals	Baseboard	VRF fan coil units
Cooling plant	Direct expansion	Direct expansion OR VRF
Cooling terminals	VAV/CAV	VAV/CAV OR VRF FCU
Ventilation energy recovery	50%	75%
Lighting	0.61 watts/sf average across whole building	

# Primary School - target heating fuel reduction




## Heating Energy - TEDI



# Primary School – maintain or reduce electric demand



## Electricity – Monthly Peak Demand




# Case study: 328,000-sf secondary school

Item	Current Stretch Code	Proposed Stretch Code
Roof	R-40	R-45
Wall	R-19 + 8.4 c.i.	R-19 + 21 c.i.
Thermal breaks	None	Included
% fenestration	22%	
Fixed window	U-0.32 (R-3.1 equiv)	U-0.23 (R-4.3 equiv)
Operable window	U-0.38 (R-2.6 equiv)	U-0.28 (R-3.6 equiv)
Infiltration	1 cfm at 75 Pa	0.4 cfm at 75 Pa
Infiltration testing	No	Yes
Heating plant	Gas mid-efficiency	Gas condensing OR central heat pump
Heating terminals	VAV and baseboard	Fan coil units
Cooling plant	Water cooled chiller with direct expansion RTUs	
Cooling terminals	VAV	Fan coil units, constant air volume terminals
Ventilation energy recovery	50%	75%
Lighting	0.61 watts/sf average across whole building	

# Secondary School




## Heating Energy - TEDI



# Secondary School

## Electricity – Monthly Peak Demand





Questions?

---

Contact DOER:

---

[Stretchcode@mass.gov](mailto:Stretchcode@mass.gov)

---

Paul Ormond

---

Ian Finlayson

# Study Teams

Commercial and large multifamily



**BURO HAPPOLD**

Residential low rise

